

Test Certificate



Tests Conducted By:

Site: SITE 1

Location: LOC. 1

Asset: EXTENSION Description: EXTENSION 1.5M Testcode: J6B700A012 Q121111111
Make: Model: Serial No:

Test	Result	Unit	Status
Visual			Pass
Earth Current	25	A	Information
Earth	<0.04	Ohm	Pass
Insulation	>99.99	MOhm	Pass
Leakage	<0.1	mA	Pass
Load	<0.05	kVA	Information
Polarity			Pass

Comments:

Overall Status: Pass

Date Of Test: 01/06/2008

Test Instrument: Seaward Europa Plus Y40-0916

Tested By: DAN

Signed By: